

Dear All,

On behalf of Daya Bersih Sdn Bhd, I would like to invite you to bid price, as below details:

No	Descriptions
1	Date: 7/2/2023
2	Proposed: Replace SF6 gas at breaker ABB, replace cable, and repair faulty transformer no 2, at PPU International Islamic University Malaysia Kuantan Campus.

The details are as follows:				
	Descriptions	Unit	RM	Total (RM)
	Mobilization and demobilization, load, unloading and transport of tools and equipment.	1 lot		
	To provide insurance for project and equipment for the unexpected	1 lot		
	To provide competencies 33kV for switching and PTW (7 Days).	1 lot		
	<p>Breaker 33kV</p> <p>To carry out gas SF6 replacement work for panel ABB breaker H3, H4 and H5 .</p> <ul style="list-style-type: none"> -To recover existing SF6 into empty cylinder - To open gas compartment, inspect and clean the compartment breaker H3,H4 and H5. -To replace drying agent/desiccant with new - To close back the compartment with new O-ring - To vacuum the compartment and fill up with new gas SF6 - To carry out leak test <p>To check the newly filled SF6</p>	3 nos		

<p>33KV ABB GIS testing</p> <ul style="list-style-type: none"> - IR test -Contact resistance test - CB timing test - Operation and interlock test - AC pressure test - Relay 33KV check and trip test <ul style="list-style-type: none"> i. OCEF ii. Transformer Differential test iii. REF test <p>To provide test plug for testing breaker gis ABB</p> <p>Refer from attachment name plate Breaker ABB 33kV</p>	2 nos		
To supply and install heater	6 nos		
Replace timer	1 nos		
<p>Transformer 33kV</p> <p>Mobilization and demobilization as per contract</p> <ul style="list-style-type: none"> - load, unloading and transport of oil filtration machine, Skid tank/drum, tools, hoses and equipment. 	1 lot		
<p>To supply and replace gasket parts that is causing the leakage.</p> <ul style="list-style-type: none"> -5 sheet 6.4mm Nebar white gasket -Donut/oil seal for LV bushing – gasket cable box 33kV & 11kV 	1 lot		
<p>Transformer repair work as below:-</p> <ul style="list-style-type: none"> -To drain out oil below bushing level inside skid tank/clean empty drums. -To replace gasket at LV bushing that causing the leakage 	1 lot		

<ul style="list-style-type: none"> -To refill previously drained oil through filtration machine. -To painted transformer after service work - to cleaning bushing 33kV and 11kV - to repair cable box chasing - to supply and replace all bolt and nut broken . *include supply mobile crane for lifting top cover work 			
<p>OLTC Servicing Work:-</p> <ul style="list-style-type: none"> -Supply manpower ABB OLTC trained specialist, tools and transportation to carry out servicing of one unit of ABB OLTC type UBBRT 350/400 - Gasket for OLTC cover -To replace the oil in OLTC compartment via filtration machine -To carry out filtration until oil test the oil dielectric strength >60kV shall meet before energized the transformer -To supply 6 drum new transformer oil <p>*to provide certificate of OLTC ABB specialist</p> <p>Refer from attachment name plate OLTC</p>	1 lot		
<p>To perform filtration of transformer oil inside main tank after service work (not more 60 deg Celcius and results BDV>60kV, Moisture<15ppm) 24 hour to repair result paper/coil wet (lembab)</p> <ul style="list-style-type: none"> - to perform testing FDS/DFR (Frequency Domain Spectroscopy/Dielectric Frequency Response)test and Tan Delta test to compare first result transformer. <p>In case result paper/coil fail filtration 48 hour need to do. (moisture % below 2%)</p> <p>* refer table insulation assessment</p>	1 lot		
<p>To perform filtration of transformer oil inside maintank after service work (not more 60 deg Celcius and results BDV>60kV, Moisture<15ppm) 48 hour to repair result paper/coil wet (lembab)</p> <ul style="list-style-type: none"> - to perform testing FDS/DFR (Frequency Domain Spectroscopy/Dielectric Frequency 	1 lot		

	<p>Response) test and Tan Delta test to compare 24 hour filtration result tranfomer.</p> <p>To perform oil test before and after leak repair :- Measure dielectric strength (BDV) water content (ppm)</p>			
	<p>To collect transformer oil sample after filtration and send it to accredited lab for oil analysis. Analysis to be carried out: DGA (Maintank only) BDV (Maintank and OLTC) Moisture Content (Maintank and OLTC)</p>	1 lot		
	<p>To perform electrical testing for transformer: -Insulation resistance -Polarization Index -Turn Ratio -Static winding resistance test -Functional tx guard - Dynamic winding resistance</p> <p>Refer from attachment name plate transformer</p>	1 lot		
	<p>Cable</p> <p>To provide manpower, tools, equipments and standard accessories to lay HT cables (cabling works) in cable trench as follows:</p> <p>To supply and lay 3 x 1-Core 240mm² Copper XLPE/ SWA/PVC cable from 33kV Gis – Outgoing to transformer 33kV including necessary accessories</p> <p>To carry out termination works for 3 x 1-Core 240mm² Copper XLPE/ SWA/PVC cable from Feeder 33kV Gis ABB breaker and Outgoing to transformer 33kV including materials and standard / necessary accessories</p> <p>To provide manpower, equipments, tools and accessories to carry out commissioning test of the above inclusive of Insulation Resistance & Pressure test</p>	<p>25 mtr</p> <p>1 lot</p> <p>1 lot</p>		

***Warranty Period 1 year for service and repair work**

Insulation assessment					
Measurement:	CHG: (1)				
Capacitance, pF:	17392	%DF:	1.92		
%DF @ 20°C:	1.38	< 0.30% <i>As new</i>	0.30-0.50% <i>Good</i>	0.50-1.0% <i>Deteriorated</i>	> 1.0% <i>Investigate</i>
Moisture, %:	3.5	< 1.0% <i>As new</i>	1.0-2.0% <i>Dry</i>	2.0-3.0% <i>Moderately wet</i>	> 3.0% <i>Wet</i>
Oil Cond, @ 25°C, pS/m:	4.26	< 0.37 pS/m <i>As new</i>	0.37-3.7 pS/m <i>Good</i>	3.7-37 pS/m <i>Service aged</i>	> 37 pS/m <i>Deteriorated</i>