

SENARAI SKOP KERJA DAN HARGA (BQ)

NAMA BAHAGIAN/UNIT : HT TEAM

QUOTATION TO CARRY OUT SERVICING AND MAINTENANCE OF STANDBY GENSET 175kVA (140kW) MODEL VOLVO PENTA TID71AG

Item	Description	Quantity	Rate (RM)	Total (RM)
	SERVICING OF STANDBY GENSET			
	Servicing and testing of 175kVA Standby Generator Set complete with replacement of part as follows:			
	Fuel Filter	2 nos		
	Oil Filter	1 nos		
	Air Filter	1 nos		
	Lubricating Oil	20 liter		
	Bypass Filter	1 nos		
	Fan Belt	1 set		
	Alternator Belt	2 nos		
	Actuator Solenoid	1 nos		
	Return Spring	1 nos		
	Cable kit	1 nos		
	Feeder pump	1 set		
	Coolant 5L	4 nos		
	Re-flushing Radiator & Top-up Coolant	1 lot		
	Labour charge to check, service and clean the Gen-Set c/w tuning the engine	1 lot		
	Test run the Gen-Set after servicing	1 lot		
	MSB Panel			
	Supply and install Selector Switch 2-points	3 nos		
	Supply and install Selector Switch 4-points	1 nos		
	Supply and install indicator led light	4 nos		
	Batteries			
	Supply and install Battery nickel cadmium (24v 24AH) complete charger bateri for genset 175kVa	1 set		

**For any inquiries, kindly contact our person in charge En. KHALDI 013-3338416
or En. MAS NIZAM 0122607932
HT CHARGEMAN DBSB**

FIG 1 BATTERY CHARGER



FIG 2 SWITCHES CHARGER PANEL



FIG 3 ALTERNATOR NAME PLATE



FIG 4 ENGINE MODEL



FIG 5 PART OF ENGINE



FIG 6 PART OF ENGINE

